



मिरा-भाईंदर महानगरपालिका

स्व. इंदिरा गांधी भवन, छत्रपती शिवाजी महाराज मार्ग, भाईंदर(प)

पाणी पुरवठा व मलनिःसारण विभाग

ई-मेल - watersupply@mbmc.gov.in

संकेतस्थळ - www.mbmc.gov.in

संपर्क - 281922828-251



जा.क्र.मनपा/पापु व मलनि/ २५०९ /2023-24

दि.०८/०२/2024

प्रति,
सिस्टम मॅनेजर
संगणक विभाग
मिरा-भाईंदर महानगरपालिका

विषय :- मिरा भाईंदर महानगरपालिका क्षेत्रातील चवळी पंपिंग स्टेशन येथे नविन पंप पुरविणे, बसविणे व कार्यान्वित करणे.

मिरा भाईंदर महानगरपालिका क्षेत्रातील चवळी पंपिंग स्टेशन येथे नविन पंप पुरविणे, बसविणे व कार्यान्वित करणे या कामाची निविदा मागविणेकरीता अंदाजपत्रक तयार करावयाचे आहे. परंतु सदर कामाअंतर्गत खालील नमुद बाबींकरीताचे दर दरसुचीमध्ये उपलब्ध नसल्याने ऑन-लाईन दर www.mbmc.gov.in या संकेत स्थळावर मागविणे करीता सोबत जोडलेल्या बाबींचा तक्ता आनलाईन प्रसिध्द करण्यात यावा.

शहर अभियंता

मिरा-भाईंदर महानगरपालिका



MIRA-BHAINDAR MUNICIPAL CORPORATION
Water Supply & Sewerage Department
Indira Gandhi Bhavan, Chatrapati Shivaji Maharaj Marg,
Bhayandar (W) 401101, Tal. Dist – Thane, 28192828



Mira Bhaindar Municipal Corporation Want to Float a tender of Supply, Installation, Testing and Commissioning of Centrifugal Pump at Chawli Pumping station in mira Bhayander Mucipal Corporation Area. For this Municipal Corporation need online rates of the items mentioned in following chart.

The rates will be Quoted on watersupply@mbmc.gov.in from Dt.08/02/2024 to Dt.14/02/2024 upto 12.00 noon.

Sr.No.	DESCRIPTION OF WORK	Qty	Unit	Rate (Excluding GST)
1.	CENTRIFUGAL PUMP (alongwith coupling, base frame and coupling cover) - without Motor Operating data : flow rate - 150.00 m ³ /h, developed head- 38.00 m, discharge pressure- 3.70 bar, Efficiency- 79.1 %, Power absorbed- 19.47 kW, Pump speed of rotation- 1478 rpm, NPSH required- 2.06 m, Max. power on curve -25.58 kW, Min.allow. flow for continuous stable operation- 30.39 m ³ /h, Design : Pump standard- EN 733, Casing -drain Drilled and plugged, Design - Baseplate mounted, longcoupled, Orientation -Horizontal, Shaft seal - Single acting mechanical seal, Recommended pipe size suction -DN 125, Recommended pipe size Discharge - DN100, Impeller diameter- 333.0 mm, Bearing seal- V ring, Bearing type- Anti-friction bearings, Lubrication type- Grease. Accessories : Coupling - LOVEJOY, Nominal size- 190, Spacer length- 140.0 mm, Coupling guard type- Lightweight, Guard size- BZH08, Guard material- Steel ST, Baseplate type- Welded steel, Baseplate size- BF101672, Baseplate drain- Drip tray, Baseplate fixing- Foundation bolts galvanized steel.	01	NO	


City Engineer

Mira Bhaindar Municipal Corporation

No :- MNP/WS & Sew/ /2023-24
Date :-