



मिरा भाईंदर महानगरपालिका



स्व. इंदिरा गांधी भवन, मुख्य कार्यालय, छत्रपती शिवाजी महाराज मार्ग,
भाईंदर (प.), ता.ठाणे-४०११०१ दुरध्वनी क्रं.२८१९२८२८

बांधकाम / विद्युत विभाग

जा.क्र. मनपा/साबां/विद्युत/ 9354 /2024-25
दि. 9/10/2024

प्रति,
सिस्टीम मॅनेजर
माहिती तंत्रज्ञान विभाग तथा जनसंपर्क अधिकारी
मिरा भाईंदर महानगरपालिका

विषय :- जाहीर सुचना वृत्तपत्रात व महानगरपालिकेच्या संकेतस्थळावर प्रसिध्द करणेबाबत.

महोदय,

उपरोक्त विषयांकित मिरा भाईंदर महानगरपालिका क्षेत्रात काशिगाव आरक्षण क्र.318 येथील इमारतमध्ये काशिगाव पोलिस स्टेशन येथे वातानुकूलित यंत्रणा व एक्झॉस्ट फॅन बसविणेकामी सोबत जोडण्यात आलेली कोटेशन नोटीस महानगरपालिकेच्या अधिकृत संकेत स्थळावर तसेच स्थानिक वृत्तपत्रांमध्ये प्रसिध्द / upload करण्यात यावी.

(नितिन मुकणे)

कार्यकारी अभियंता (साबां/विद्युत)
मिरा भाईंदर महानगरपालिका



MIRA BHAINDAR MUNICIPAL CORPORATION
PWD / Electrical Department
Indira Gandhi Bhavan, Chhatrapati Shivaji Maharaj Marg,
Bhaindar (W) 401101,
Tal. Dist – Thane, Ph. 28192828

// RATE FORM //

Name of Work :- Rate for material require for Supply, Installation, Testing and Commissioning of Fresh Air System & Exhaust Air System at Kashigaon Police Station Kashmirira Mira road IN MBMC AREA..

Name and address of Contractor :-

B-2 FORM

Sr. No.	Description	Qty	UNIT	RATE
FRESH AIR SYSTEM				
1	Item No. 1 Cabinet type fan section for Fresh Air Supply, Installation, testing and commissioning of fresh air fans with filters 900 cfm Cabinet Type Fresh air fan upto 25 mm ESP	1.00	Nos	
	SITC of rectangular Ducts as per SMACNA/IS standards with Supports from structural ceiling to the ducts using 8 MM threded GI rods and GI slotted section supports hung by GI Anchor fasteners.			
2	Item No. 2 24/26 gauge	112.00	Sq.m	
3	Item No. 3 SITC of Canvas connection	1.00	Nos	
4	Item No. 4 SITC of flexible Duct 100 Mm dia	30.00	Rmt	
5	Item No. 5 SITC of Bird Screen	1.00	Nos	
6	Item No. 6 Spot grille 150*150	20.00	Nos	
EXHAUST AIR SYSTEM				
7	Item No. 7 Cabinet type fan section for Exhaust Air Supply, Installation, testing and commissioning of EA fans1100 cfm Cabinet Type exhaust air fan upto 25 mm ESP	1.00	Nos	
	SITC of rectangular Ducts as per SMACNA/IS standards with Supports from structural ceiling to the ducts using 8 MM threded GI rods and GI slotted section supports hung by GI Anchor fasteners.			

8	Item No. 8 24/26 gauge	115.00	Sq.m	
9	Item No. 9 SITC of Canvas connection	1.00	Nos	
10	Item No. 10 SITC of flexible Duct 100 Mm dia	30.00	Rmt	
11	Item No. 11 SITC of Bird Screen	1.00	Nos	
12	Item No. 12 Spot grille 150*150	20.00	Nos	
13	Item No. 13 Lifting shifting, loading unloading of total HVAC accessories	1.00	Lot	

PC-03/PJ/2023-24/L-504